

**Trus Joist Product Technical Support**

Phone: (888) 453-8358

Email: TechSupport@wy.com



Weyerhaeuser prepared this drawing for the specification of Trus Joist products based on project information provided to us. This service is solely intended for product application assurance, and is not intended to circumvent the need for a design professional as determined by the building codes. The designer of record and/or builder/framer is responsible to assure these drawings are compatible with the over all project.  
Copyright 2019 Weyerhaeuser NR Company. All rights reserved. Any unauthorized copying or reproduction will constitute an infringement of copyright.

MAXIMUM ACCESS OPENING SIZE OF 18"x24", OR PER DESIGNER OF RECORD

FLOOR SHEATHING NAILED AT 6" O.C. TO 2x\_ SUPPORT

DO NOT DAMAGE TJI FLANGE WHEN CUTTING ACCESS HOLE OR WHEN REMOVING FLOOR

SECTION A-A

MAXIMUM 24" O.C.

FLOOR SHEATHING NAILED OFF TO I-JOIST

2x6 HEM-FIR #2 OR BETTER

SIMPSON STRONG-TIE Z2 CLIP, INSTALLED PRIOR TO SHEATHING

SECTION A-A

MIN. (2) 8d PNEUMATIC NAILS

2x4 HEM-FIR STANDARD OR BETTER, GLUED & NAILED

(4) TOTAL 8d PNEUMATIC NAILS EACH SIDE, (2) END NAILED INTO EACH 2x4

2-PLY 2x4 HEM-FIR STANDARD OR BETTER TO SUPPORT FLAT 2x4

(4) 8d PNEUMATIC NAILS, STAGGERED TO CONNECT 2-PLY 2x4 UNDER NAILER

ALTERNATE INSTALLATION OPTION - 3 PIECE ASSEMBLY

**NOTE**

- FLOOR SHEATHING FIELD NAILING NOT SHOWN FOR CLARITY  
- 8d PNEUMATIC NAIL SIZE: (0.131"x3")

**CRAWL SPACE ACCESS DETAIL**

EXPIRATION DATE: JANUARY 2025

PROJECT #:

SERVICE #:

SHEET:

NW-D222